

**GOVERNMENT OF WEST BENGAL  
OFFICE OF THE DIVISIONAL FIRE OFFICER  
WEST BENGAL FIRE & EMERGENCY SERVICES  
S.F. Road, P.O. - Siliguri, P.S. - Siliguri Bazar, Pin -  
734005**

Memo No : IND/WB/FES/20192020/60256

DATE: 03/07/2019

From :

The Divisional Fire Officer  
Fire Prevention Wing,  
West Bengal Fire & Emergency Services.

To :

THE TECHNO INDIA GROUP PUBLIC SCHOOL New Building  
SIT Complex, Sukna, Siliguri, Darjeeling  
Siliguri F.S., Siliguri,  
Darjeeling - 734009 .

Sub :Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 2 storied building under group Educational at the premises no.- SIT Complex, Sukna, Siliguri, Darjeeling, Siliguri, Darjeeling - 734009

This is in reference to your Application No. IND/WB/FES/20192020/60256, dated 03/07/2019, regarding the Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 2 storied building under group Educational at the premises no.- SIT Complex, Sukna, Siliguri, Darjeeling, Siliguri, Darjeeling - 734009.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. Subject to fulfillment following conditions

- 1) Good housekeeping to be maintained both inside as well as outside the building
- 2) Floor Numbers as well as directional signs of escape routes to be prominently displayed

- 3) Fire Notice for evacuation and fire fighting to be prepared to display at all vulnerable places in the building
- 4) The occupants, employees and security staff to be made well-conversant about the installed fire safety and protection measures for their use in exigencies
- 5) Mock practice and fire evacuation drills to be organized for the regular periodical performance in accordance to the National Building Code - Part IV.
- 6) Electrical wiring of the afore said building should be checked and maintenance to be done by an licensed electrician.
- 7) Trained Firemen and Fire Officers in the form of prescribed crew to be maintained for round the clock safety of the establishment.
- 8) Mock practice and fire evacuation drills to be organized for the regular periodical performance in accordance to the National Building Code - Part IV.
- 9) All Exit & Entrance should be free from obstruction.

This certificate is valid for 3 year from the date issue u/r 18 of WBFS ( Fire Prevention and Safety) Rules, 2018 (Amendment) and renewable after three year failing which this shall be revoked automatically.

**Divisional Fire Officer**  
**West Bengal Fire & Emergency Services**

Signature valid

Digitally signed by ASISH  
KUMAR PUTTANDA

Date: 2019.07.03 17:12:15 IST



**GOVERNMENT OF WEST BENGAL  
OFFICE OF THE DIVISIONAL FIRE OFFICER  
WEST BENGAL FIRE & EMERGENCY SERVICES  
S.F. Road, P.O. - Siliguri, P.S. - Siliguri Bazar, Pin -  
734005**

Memo No : IND/WB/FES/20192020/60249

DATE: 03/07/2019

**From :**

The Divisional Fire Officer  
Fire Prevention Wing,  
West Bengal Fire & Emergency Services.

**To :**

THE TECHNO INDIA GROUP PUBLIC SCHOOL  
SIT complex, Sukna, Darjeeling  
Siliguri F.S., Siliguri,  
Darjeeling - 734009 .

**Sub :Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 3 storied building under group Educational at the premises no.- SIT complex, Sukna, Darjeeling, Siliguri, Darjeeling - 734009**

This is in reference to your Application No. IND/WB/FES/20192020/60249, dated 03/07/2019, regarding the Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 3 storied building under group Educational at the premises no.- SIT complex, Sukna, Darjeeling, Siliguri, Darjeeling - 734009.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. Subject to fulfillment following conditions

- 1) Good housekeeping to be maintained both inside as well as outside the building
- 2) Floor Numbers as well as directional signs of escape routes to be prominently displayed

- 3) Fire Notice for evacuation and fire fighting to be prepared to display at all vulnerable places in the building
- 4) The occupants, employees and security staff to be made well-conversant about the installed fire safety and protection measures for their use in exigencies
- 5) Mock practice and fire evacuation drills to be organized for the regular periodical performance in accordance to the National Building Code - Part IV.
- 6) Electrical wiring of the afore said building should be checked and maintenance to be done by an licensed electrician.
- 7) Trained Firemen and Fire Officers in the form of prescribed crew to be maintained for round the clock safety of the establishment.
- 8) Mock practice and fire evacuation drills to be organized for the regular periodical performance in accordance to the National Building Code - Part IV.
- 9) All Exit & Entrance should be free from obstruction.

This certificate is valid for 3 year from the date issue u/r 18 of WBFS ( Fire Prevention and Safety) Rules, 2018 (Amendment) and renewable after three year failing which this shall be revoked automatically.

**Divisional Fire Officer**  
**West Bengal Fire & Emergency Services**

Signature valid

Digitally signed by ASISH  
KUMAR PUTTANDA  
Date: 2019.07.03 17:10:40 IST