



**Government Of West Bengal
Office Of The Divisional Fire Officer,Darjeeling
West Bengal Fire & Emergency Services
Station Feeder Road, P.O & P.S Siliguri,
District: Darjeeling, Pin - 734005**

Memo no.:IND/WB/FES/20192020/60256

Date: 05-11-2022

From:

**Divisional Fire Officer,Darjeeling
West Bengal Fire & Emergency Services**

**To: THE TECHNO INDIA GROUP PUBLIC SCHOOL New Building
SIT Complex,Sukna,Siliguri, Dist- Darjeeling, Pin- 734009**

**Sub: Renewal of Fire Safety Certificate for the G+2 Storied School building under group Educational in name of
THE TECHNO INDIA GROUP PUBLIC SCHOOL New Building at SIT Complex,Sukna,Siliguri, Dist- Darjeeling, Pin-
734009**

This is in reference to your application no. 0125191220500312 dated 20-09-2022 regarding the Renewal of Fire Safety Certificate for the G+2 Storied School building under group Educational in name of THE TECHNO INDIA GROUP PUBLIC SCHOOL New Building at SIT Complex,Sukna,Siliguri, Dist- Darjeeling, Pin- 734009

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

- 1) Regular checking, testing and maintenance of fire safety systems/installations are must.
- 2) Good housekeeping to be maintained.
- 3) Regular checking and maintenance of electrical wiring and installation by a licensed Electricians.
- 4) Regular mock fire drill and evacuation drill should be conducted by participation of all and for this purpose a special crew should be formed.
- 5) Certificate shall have to be obtained from this Office on routine basis about the satisfactory performances off all the fire and life safety installations failing which the Fire Safety Certificate shall be revoked as per rule 18 of the W.B. fire Services (Fire Prevention & Fire Safety) Rules, 2003.

Fire License shall be obtained from this department separately which are attracts section 12 of FS Act.

- 7) This certificate needs to be renewed after 3(three) yrs as per notification subject to ensure safety first and all safety measures should be in working condition at all time failing which this certificate will automatically liable to be cancelled.
- 8) Occupancy of the building shall not be allowed to change without the concurrence of this department and floor area, height etc. shall not permissible to enhance without the concurrence of this department .No addition or alteration should be allowed without the prior approval of this department
- 9) Minimum Two staircases/exits should be free from any obstruction at all time
- 10) Auto panel , pumps and all safety measures should be in working condition at all time and if any defects or if found the safety measures not in working condition then this certificate will automatically liable to be cancelled in the life safety point of view or it will be revoked in the same causes.

Signature Not Verified

Digitally Signed
Name: PRADIP SARKAR
Date: 09-Nov-2022 21:05:08
Reason: Approved
Location: West Bengal

Divisional Fire Officer, Darjeeling
West Bengal Fire & Emergency Services



Government Of West Bengal
Office Of The Divisional Fire Officer, Darjeeling
West Bengal Fire & Emergency Services
Station Feeder Road, P.O & P.S Siliguri,
District: Darjeeling, Pin - 734005

Memo no.: IND/WB/FES/20192020/60249

Date: 05-11-2022

From:

Divisional Fire Officer, Darjeeling
West Bengal Fire & Emergency Services

To: THE TECHNO INDIA GROUP PUBLIC SCHOOL

SIT complex, Sukna, P.S.- Matigara, Dist- Darjeeling, Pin- 734009

Sub: Renewal of Fire Safety Certificate for the G+3 Storied School building under group Educational at SIT complex, Sukna, P.S.- Matigara, Dist- Darjeeling, Pin- 734009.

This is in reference to your application no. 0125191220500290 dated 10-09-2022 regarding the Renewal of Fire Safety Certificate for the G+3 Storied School building under group Educational at SIT complex, Sukna, P.S.- Matigara, Dist- Darjeeling, Pin- 734009.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

- 1) Regular checking, testing and maintenance of fire safety systems/installations are must.
- 2) Good housekeeping to be maintained.
- 3) Regular checking and maintenance of electrical wiring and installation by a licensed Electricians.
- 4) Regular mock fire drill and evacuation drill should be conducted by participation of all and for this purpose a special crew should be formed.
- 5) Certificate shall have to be obtained from this Office on routine basis about the satisfactory performances off all the fire and life safety installations failing which the Fire Safety Certificate shall be revoked as per rule 18 of the W.B. fire Services (Fire Prevention & Fire Safety) Rules, 2003.
- 6) Fire License shall be obtained from this department separately which are attracts section 12 of FS Act.

7) This certificate for the School bld(without hostel) needs to be renewed after 3(three) yrs as per notification subject to ensure safety first and all safety measures should be in working condition at all time failing which this certificate will automatically liable to be cancelled.

8) Occupancy of the building shall not be allowed to change without the concurrence of this department and floor area, height etc. shall not be permissible to enhance without the concurrence of this department. No addition or alteration should be allowed without the prior approval of this department

9) Minimum Two staircases/exits should be free from any obstruction at all time

10) Auto panel, pumps and all safety measures should be in working condition at all time and if any defects or if found the safety measures not in working condition then this certificate will automatically liable to be cancelled in the life safety point of view or it will be revoked in the same causes.

Validity unknown

Digitally Signed
Name: PRODDIP SARKAR
Date: 05-Nov-2022 16:16
Reason: Approved
Location: West Bengal

Divisional Fire Officer, Darjeeling
West Bengal Fire & Emergency Services